Message

From: Thomas Lee [/o=Inglewood/ou=Exchange Administrative Group

(FYDIBOHF23SPDLT)/cn=Recipients/cn=613c9210dca34c17b02de860ef5e5955-Thomas Lee]

on behalf of Thomas Lee

Sent: 5/14/2019 10:37:49 AM

To: 'Chris Holmquist' [CHolmquist@wilsonmeany.com]

CC: Barmeshwar Rai [/o=Inglewood/ou=Exchange Administrative Group

(FYDIBOHF23SPDLT)/cn=Recipients/cn=9f05f6278a8f42959478fccdcc711a68-Barmeshwar Rai]

Subject: RE: Utilities check on Clippers Arena/Well 8.....5/14/2019 **Attachments**: SewerIndexMap.pdf; StormDrainIndex.pdf; WaterIndexMap.pdf

Hi Mr. Holmquist,

I checked on the utilities on 102nd street between Prairie Avenue and Doty Avenue, where Clippers Arena located. For utilities:

- 1) Storm Drain you will need new connection to LAC Storm main line @the Doty Avenue. If the Clippers Arena is connecting at this location, please consider the flow from arena and Well 8 <u>separately</u> because Inglewood rarely (near none) discharge any water from the well during the rain.
- 2) Water line Inglewood 27" RCP raw water transmission line to be re-routed and connect back in on Prairie and 102nd Street. Clippers arena will plan their own water line with Golden State Water Company for water supply.
- 3) Sewer since the existing sewer's high point is at middle and flows are going to both East & West direction. New public sewer main line may not need, but it will be Clippers arena's private sewer line. For sewer connection to the West @Prairie, you will need the new sewer permit from Inglewood Planning department. For sewer connection to the East @Doty Avenue, you will need the new sewer permit from *L.A. County Sanitation District*.

Attachments are for your information only. Thank you.

Sincerely,

Thomas C. Lee, Associate Engineer, P.E. & M.S. City of Inglewood Public Works Dept. Water Division 1 West Manchester Blvd #300, Inglewood, CA 90301 Office: (310)412-5333 Ext. 5611 / Fax: (310)412-5552

From: Chris Holmquist [mailto:CHolmquist@wilsonmeany.com]

Subject: RE: FYI - tasks for each contractor to do on a new well

Thank you Thomas!

Chris Holmquist
Wilson Meany
6701 Center Drive, Suite 950
Los Angeles, CA 90045

Phone: (310) 382-9023 Mobile: (415) 298-3230 From: Thomas Lee < tlee@cityofinglewood.org>

Sent: Thursday, May 9, 2019 4:39 PM

To: Chris Holmquist < CHolmquist@wilsonmeany.com > **Cc:** Barmeshwar Rai < brai@cityofinglewood.org >

Subject: FYI - tasks for each contractor to do on a new well

Hi Mr. Holmquist:

Per our meeting today, the works to be done by each contractor on a new well:

1) General Contractor (Contractor License A):

BID1 #CB-17-07 -New Well 7 Site Improvements - Bid Table.pdf

2) Well Driller (Contractor License C57 well drilling required):

BID2 #CB-17-08 -New Well 7 Drilling Equipping - Bid Table.pdf

Also you will need the hydrogeologist Consultant (Richard C. Slade Associates) during the construction; they will help during the construction and determine the final well design. They will give you all required reports (Well Construction report, Well Completion reports, DWSAP, etc.) to be submitted and filed with State Water Resources Control Board-Department of Drinking Water (SWRCB-DDW), which assign final well ID.

For Your Reference/Information Only.

Sincerely,

Thomas C. Lee, Associate Engineer, P.E. & M.S. City of Inglewood Public Works Dept. Water Division 1 West Manchester Blvd #300, Inglewood, CA 90301 Office: (310)412-5333 Ext. 5611 / Fax: (310)412-5552

Note: To protect against computer viruses, e-mail programs may prevent sending or receiving certain types of file attachments. Check your e-mail security settings to determine how attachments are handled.