

Calculation Summary table with columns: Label, CalcType, Units, Avg, Max, Min, Avg/Min, Max/Min. Lists various locations like 101st St 1, 102nd St 1, Century Blvd 1, etc.

PROJECT
IBC PROJECT
INGLEWOOD, CALIFORNIA

DEVELOPER
MURPHY'S BOWL
LLC

DEVELOPER'S MANAGING AGENT
WILSON MEANY

ARCHITECT / PLANNING / ENGINEERING / TRANSPORTATION
AECOM

AECOM
AECOM TECHNICAL SERVICES, INC.

2300 McGee, Suite 200
Kirkland, WA 98033
916.961.2863 fax
www.aecom.com

CIVIL ENGINEER
D&D ENGINEERING, INC.

8601 S. La Cienega Blvd. Suite 106
Inglewood, CA 90301
424.351.6600 ext

DRY UTILITY SYSTEMS
BJ PALMER & ASSOCIATES, INC.

26245 Crocker Avenue
Van Nuys, CA 91411
760.842.7510 ext

PARKING
WALKER CONSULTANTS

606 S. Olive St, Suite 1100
Los Angeles, CA 90014
213.462.4511

SHORING ENGINEER
DRS ENGINEERING, INC.

3564 Sagunto Street, Suite 460
Santa Ana, CA 92705
949.402.3992 ext

REGISTRATION

This drawing has been prepared for the use of AECOM's client and may not be used, reproduced or relied upon by third parties, except as agreed by AECOM and its client, as required by law or for use by governmental reviewing agencies. AECOM accepts no responsibility, and denies any liability whatsoever, to any party that modifies this drawing without AECOM's express written consent. Do not scale this drawing. All measurements must be obtained from the stated dimensions.

NOT FOR CONSTRUCTION

ISSUE/REVISION

Table with 3 columns: No., Date, Description. Empty rows for issue tracking.

Month 15, 2019 EIR DOCUMENTS

KEY PLAN

PROJECT NUMBER
60545923

SHEET TITLE
EIR PHOTOMETRICS BASE - SCHEDULES

SHEET NUMBER
E104

© 2018 AECOM TECHNICAL SERVICES, INC.

LIGHTING FIXTURE SCHEDULE table with columns: TYPE, MANUFACTURER, CATALOG NUMBER, LAMP, WATTS, COLOR TEMP, VOLTS, MOUNTING, DESCRIPTION, BALLAST/DIMMING. Lists various fixture types like HE WILLIAMS LIGHTING, SPECGRADE LED, EATON-METALUX, etc.

- 1. EXIT SIGNS DIRECTION OF FIELD INSTALLED CHEVRONS TO BE COORDINATED WITH ARCHITECTURAL/ELECTRICAL DRAWINGS. PROVIDE 15% EXTRA OF QUANTITY SHOWN IN PLANS FOR EACH TYPE OF EXIT SIGN, AND NO LESS THAN 1 FOR EACH TYPE.
2. ALL FIXTURES SHALL BE SUPPLIED WITH LAMPS AND ALL EQUIPMENT FOR A COMPLETE INSTALLATION. FIRST LISTED FIXTURE TO BE USED FOR ALL BASIS OF DESIGN DECISIONS. SECONDARY FIXTURE LISTED MAY NOT INCLUDE ALL OPTIONS REQUIRED FOR A COMPLETE WORKING SYSTEM.
3. LIGHTING FIXTURE CATALOG NUMBERS AND DESCRIPTIONS ARE SCHEDULED FOR ESTABLISHING QUALITY, APPEARANCE AND PERFORMANCE OF THE LISTED FIXTURE. EXACT CATALOG NUMBERS DESCRIBING MOUNTING CONDITIONS AND REQUIREMENTS RELATED TO TRIM FOR ALL FIXTURES SHALL BE CONFIRMED BY THE ELECTRICAL CONTRACTOR WITH THE ROOM FINISH SCHEDULE AND REFLECTED CEILING PLANS ON THE ARCHITECTURAL PLANS PRIOR TO BIDDING. FIXTURES SHALL BE SUBMITTED ACCORDING TO THE CONDITIONS INDICATED ON THE ARCHITECTURAL PLANS. REFER TO WRITTEN SPECIFICATIONS FOR ADDITIONAL REQUIREMENTS.
4. REFER TO SPECIFICATION SECTION 26 5100 INTERIOR LIGHTING FOR ADDITIONAL REQUIREMENTS.
5. FOR ALL CONTINUOUS RUNS OF LIGHT FIXTURES, COORDINATE EXACT QUANTITY AND LENGTH WITH ARCHITECTURAL DRAWINGS TO CREATE CLEAN, CONTINUOUS LENGTH OF LIGHT OUTPUT.
6. FIXTURE LABELS WITH SUBSCRIPT 'C' IN LIGHTING PLANS SIGNIFIES FIXTURE TO BE PROVIDED WITH 90-MINUTE BACK-UP BATTERY BALLAST.
7. DIMMABLE FIXTURES TO BE PROVIDED WITH ALL REQUIRED BALLASTS, DIMMING INTERFACES AND CIRCUITRY TO CREATE A COMPLETE WORKING SYSTEM AND SHALL BE PROGRAMMED PER ENGINEER'S AND OWNER'S REQUIREMENTS.
8. FIXTURES LABELS WITH SUBSCRIPT 'D' IN LIGHTING PLANS SIGNIFIES FIXTURE TO BE PROVIDED WITH DIMMABLE BALLAST OR DRIVER.
9. FIXTURES NOTATED WITH (E) ARE EXISTING TO REMAIN, FIXTURES NOTATED WITH (O) ARE EXISTING FIXTURES TO BE DEMOLISHED, FIXTURES NOTATED (N) ARE NEW FIXTURES TO MATCH EXISTING FIXTURES IN AREA SIMILAR IN FORM AND FUNCTION REQUIRED.
10. FOR ALL SPORTS LIGHTING FIXTURES (SP), FIRST FIXTURE LISTED WITH LAYOUTS SHOWN IN PLAN REPRESENT BASIS OF DESIGN. ALL ALTERNATE FIXTURES LISTED SHALL REQUIRE NEW LAYOUTS AND QUANTITIES TO MATCH LIGHTING REQUIREMENTS. IF ALTERNATE FIXTURE PACKAGES ARE SUBMITTED, NEW LIGHTING LAYOUTS WITH ILLUMINANCE CALCULATIONS SHALL BE PROVIDED TO VERIFY EQUIVALENCY TO BASIS OF DESIGN CALCULATIONS TO BE COMPLETED IN AGI32 OR EQUIVALENT LIGHTING CALCULATION SOFTWARE). CONTRACTOR TO COORDINATE ANY STRUCTURAL OR ARCHITECTURAL CHANGES ADDITIONAL FIXTURES OR ALTERNATE MOUNTING OPTIONS MAY INCUR.