

Message

From: Thomas Lee [/o=Inglewood/ou=Exchange Administrative Group (FYDIBOHF23SPDLT)/cn=Recipients/cn=613c9210dca34c17b02de860ef5e5955-Thomas Lee]
on behalf of Thomas Lee
Sent: 8/7/2019 3:20:04 PM
To: 'Lee, Adrian' [adrian.lee@tetrattech.com]
CC: Barmeshwar Rai [/o=Inglewood/ou=Exchange Administrative Group (FYDIBOHF23SPDLT)/cn=Recipients/cn=9f05f6278a8f42959478fccdcc711a68-Barmeshwar Rai]
Subject: Lot Layout for Inglewood Well 8 + design consideration.....8/7/2019
Attachments: ParcelMap Well 8 Lot Layout.pdf

Hi Adrian,

Since you have crew to do survey couple weeks ago, I forgot to mention to you and Tetra that the proposed lot for Inglewood New Well 8 may be used by Inglewood Public Works Department-Water Division entirely. Inglewood Water Division will have the lot as "well field".

Per discussion with Layne (well driller), minimum offset distance to build new one next old one (to be abandoned) is 50 feet. Since the size of the lot located 3812 W. 102nd Street, Inglewood, CA (100' W x 304.09'L) is quite big, we would like to ask Tetra Tech Inc. to consider the proposed lot can be used to build/accommodate three (3) wells in your design. Please review the attached layout of the proposed lot located on 3812 W. 102nd street:

ParcelMap Well 8 Lot Layout.pdf

Please pass/forward the email to your design team, who's in charge of Inglewood New Well 8 design. Thank you very much.

Sincerely,

Thomas C. Lee, Associate Engineer, P.E. & M.S.
City of Inglewood Public Works Dept. Water Division
1 West Manchester Blvd #300, Inglewood, CA 90301
Office: (310)412-5333 Ext. 5611 / Fax: (310)412-5552

Note: City of Inglewood has run out of space and suitable location for drilling a well.

Note: To protect against computer viruses, e-mail programs may prevent sending or receiving certain types of file attachments. Check your e-mail security settings to determine how attachments are handled.