

Message

**From:** Dennis Kanuk [dennis@mcadvise.com]  
**Sent:** 5/30/2019 3:28:38 PM  
**To:** Anitra Rice [/o=ExchangeLabs/ou=Exchange Administrative Group (FYDIBOHF23SPDLT)/cn=Recipients/cn=f4d1e98f72ad44b3921aa7a6662cddc5-Anitra Rice]; Addie Farrell [/o=ExchangeLabs/ou=Exchange Administrative Group (FYDIBOHF23SPDLT)/cn=Recipients/cn=cc6bb601520a4f9690ae254948d782f5-Addie Farre]  
**CC:** Christina Erwin [/o=ExchangeLabs/ou=Exchange Administrative Group (FYDIBOHF23SPDLT)/cn=Recipients/cn=4dddbff2e8414460abdcaefc2d500dd-Christina E]; IBECproject [/o=ExchangeLabs/ou=Exchange Administrative Group (FYDIBOHF23SPDLT)/cn=Recipients/cn=88ae86133cd043eca129d9fee992fd20-0AA - IBECp]  
**Subject:** Re: Stetson Water Report

Hi, Anitra,

From Stetson, this is the expanded GPD for visitors listed in Appendix C.

GPD per Visitor	GPD per Visitor
0.1	0.088
0.1	0.125
1.1	1.100
<b>1.3</b>	<b>1.313</b>

Dennis Kanuk  
**MONTGOMERY CLARK ADVISORS**  
10877 Wilshire Blvd. Ste. 1102  
Los Angeles, CA 90024  
E-Mail: [Dennis@mcadvise.com](mailto:Dennis@mcadvise.com)  
Office: (310) 443-7711  
Mobile: (213) 309-5652

---

**From:** Anitra Rice <ARice@esassoc.com>  
**Date:** Thursday, May 30, 2019 at 1:20 PM  
**To:** Dennis Kanuk <dennis@mcadvise.com>, Addie Farrell <AFarrell@esassoc.com>  
**Cc:** Christina Erwin <CErwin@esassoc.com>, IBECproject <IBECproject@esassoc.com>  
**Subject:** RE: Stetson Water Report

Is it possible to get this breakdown for the Visitor GPD too? The total GPY is not matching up with the employee and visitor numbers which could be due to the rounding presented significant digits. Thanks.

**Anitra B. Rice**  
Managing Associate  
ESA | Environmental Science Associates  
310.566.8024 direct

---

**From:** Dennis Kanuk <dennis@mcadvise.com>  
**Sent:** Thursday, May 30, 2019 12:54 PM  
**To:** Addie Farrell <AFarrell@esassoc.com>  
**Cc:** Christina Erwin <CErwin@esassoc.com>; Anitra Rice <ARice@esassoc.com>; IBECproject

<IBECproject@esassoc.com>

**Subject:** Re: Stetson Water Report

Hi, Addie,

8.1 is the correct value – the individual demand rates listed in the table in Appendix C are rounded up in the display, but the total of all is 8.138; the expanded values in the table are below:

<b>GPD per Employee</b>	<b>GPD per Employee</b>
2.3	2.250
0.3	0.263
0.3	0.250
4.4	4.400
0.4	0.375
0.6	0.600
<b>8.1</b>	<b>8.138</b>

Dennis Kanuk

**MONTGOMERY CLARK ADVISORS**

10877 Wilshire Blvd. Ste. 1102

Los Angeles, CA 90024

E-Mail: [Dennis@mcadvise.com](mailto:Dennis@mcadvise.com)

Office: (310) 443-7711

Mobile: (213) 309-5652

---

**From:** Dennis Kanuk <[dennis@mcadvise.com](mailto:dennis@mcadvise.com)>

**Date:** Thursday, May 30, 2019 at 11:05 AM

**To:** Addie Farrell <[AFarrell@esassoc.com](mailto:AFarrell@esassoc.com)>

**Cc:** Christina Erwin <[CErwin@esassoc.com](mailto:CErwin@esassoc.com)>, Anitra Rice <[ARice@esassoc.com](mailto:ARice@esassoc.com)>, IBECproject <[IBECproject@esassoc.com](mailto:IBECproject@esassoc.com)>

**Subject:** Re: Stetson Water Report

Hi, Addie,

I'm checking with Stetson – think it might be a rounding issue, but I'll let you know when I get a response.

Thanks,

Dennis

Dennis Kanuk

**MONTGOMERY CLARK ADVISORS**

10877 Wilshire Blvd. Ste. 1102

Los Angeles, CA 90024

E-Mail: [Dennis@mcadvise.com](mailto:Dennis@mcadvise.com)

Office: (310) 443-7711

Mobile: (213) 309-5652

---

**From:** Addie Farrell <[AFarrell@esassoc.com](mailto:AFarrell@esassoc.com)>

**Date:** Wednesday, May 29, 2019 at 9:22 AM

**To:** Dennis Kanuk <[dennis@mcadvise.com](mailto:dennis@mcadvise.com)>

**Cc:** Christina Erwin <[CErwin@esassoc.com](mailto:CErwin@esassoc.com)>, Anitra Rice <[ARice@esassoc.com](mailto:ARice@esassoc.com)>, IBECproject <[IBECproject@esassoc.com](mailto:IBECproject@esassoc.com)>

**Subject:** Stetson Water Report

Hi Dennis,

In reviewing the Stetson water supply analysis, there appears to be a typo on page 34/37 of this PDF where the GPD per employee actually adds up to 8.3 GPD and not 8.1. Please confirm and update as needed.

**Addie Farrell**

Senior Managing Associate

ESA | Environmental Science Associates  
*Celebrating 50 Years of Work that Matters!*

80 South Lake Avenue, Suite 570

Pasadena, CA 91101

626.204.6170 main

626.714.4610 direct

626.204.6171 fax

[afarrell@esassoc.com](mailto:afarrell@esassoc.com) | [www.esassoc.com](http://www.esassoc.com)

Follow us on [LinkedIn](#) | [Facebook](#) | [Twitter](#) | [Instagram](#) | [Vimeo](#)