



FORM 130
Rev. 04/03

COUNTY OF LOS ANGELES FIRE DEPARTMENT
FIRE PREVENTION DIVISION

Fire Prevention Engineering
5823 Rickenbacker Road
Commerce, CA 90040
Telephone (323) 890-4125 Fax (323) 890-4129

Information on Fire Flow Availability for Building Permit

For All Buildings Other Than Single Family Dwellings (R-3)

INSTRUCTIONS:

Complete parts I, II (A) when:

Verifying fire flow, fire hydrant location and fire hydrant size.

Complete parts I, II (A), & II (B) when:

For buildings equipped with fire sprinkler systems, and/or private on-site fire hydrants.

PROJECT INFORMATION
(To Be Completed By Applicant)

PART I

Building Address: _____

City or Area: Inglewood

Nearest Cross Street: Century Blvd / Prairie Ave ; Doty Ave / 102nd Street

Distance of Nearest Cross Street: Varies

Applicant: D & D Engineering, Inc. Telephone: (424) 393-4122

Address: 8901 S. La Cienega Blvd, Suite #106


City: Inglewood, CA 90301

Occupancy (Use of Building): n/a Sprinklered: Yes No

Type of Construction: n/a

Square Footage: n/a Number of Stories: _____

Present Zoning: n/a


Applicant's Signature

9/7/17
Date

PART II-A

INFORMATION ON FIRE FLOW AVAILABILITY
(To be completed by Water Purveyor)

Location On 102nd St. ~300 ft. W/O Doty Ave.

Distance from Nearest Property Line N/A Size of Hydrant 6" Hydrant Number 1349 Size of Water main 6" AC

Static PSI 62 Residual PSI 40 Orifice size 4" Pitot 19

Fire Flow at 20 PSI 2652 GPM Duration 2Hours Flow Test Date / Time 10/23/2017 @5:36 pm

Location On Century Blvd. ~155 ft. E/O Prarie Ave.

Distance from Nearest Property Line N/A Size of Hydrant 6" Hydrant Number 4336 Size of Water main 12" DI

Static PSI 60 Residual PSI 50 Orifice size 4" Pitot 22

Fire Flow at 20 PSI 4255 GPM Duration 2 Hours Flow Test Date / Time 10/23/17 @ 5:51 pm

Location _____

Distance from Nearest Property Line _____ Size of Hydrant _____ Hydrant Number _____ Size of Water main _____

Static PSI _____ Residual PSI _____ Orifice size _____ Pitot _____

Fire Flow at 20 PSI _____ Duration _____ Flow Test Date / Time _____

PART II-B SPRINKLERED BUILDINGS/PRIVATE FIRE HYDRANTS ONLY

Detector Location (check one) Above Grade Below Grade Either

Backflow Protection Required (Fire Sprinklers/Private Hydrant) (check one) Yes No

Minimum Type of Protection Required (check one) Single Check Detector Assembly

Double Check Detector Assembly Reduced Pressure Principle Detector Assembly

Golden State Water Company
Water Purveyor

[Signature]
Signature

11/2/2017
Date

Operations Engineer
Title

This Information is Considered Valid for Twelve Months

Fire Department approval of building plans shall be required prior to the issuance of a Building Permit by the jurisdictional Building Department. Any deficiencies in water systems will need to be resolved by the Fire Prevention Division only prior to this department's approval of building plans.

PROJECT ADDRESS :



FORM 196
Rev. 04/03

**COUNTY OF LOS ANGELES FIRE DEPARTMENT
FIRE PREVENTION DIVISION**

Fire Prevention Engineering
5823 Rickenbacker Road
Commerce, CA 90040
Telephone (323) 890-4125 Fax (323) 890-4129

Information on Fire Flow Availability for Building Permit

For All Buildings Other Than Single Family Dwellings (R-3)

INSTRUCTIONS:

Complete parts I, II (A) when:

Verifying fire flow, fire hydrant location and fire hydrant size.

Complete parts I, II (A), & II (B) when:

For buildings equipped with fire sprinkler systems, and/or private on-site fire hydrants.

**PROJECT INFORMATION
(To Be Completed By Applicant)**

PART I

Building Address: _____

City or Area: Inglewood

Nearest Cross Street: 103rd Street

Distance of Nearest Cross Street: 10'

Applicant: D & D Engineering, Inc. Telephone: (424) 393-4122

Address: 8901 S. La Cienega Blvd, Suite #106


City: Inglewood, CA 90301

Occupancy (Use of Building): n/a Sprinklered: Yes No

Type of Construction: n/a

Square Footage: n/a Number of Stories: _____

Present Zoning: n/a



Applicant's Signature

11/14/2017

Date

PART II-A

INFORMATION ON FIRE FLOW AVAILABILITY
(To be completed by Water Purveyor)

Location On S. Prairie Ave. ~284 ft. S/O W. 102st.

Distance from Nearest Property Line 10' Hydrant Number 1351
Size of Hydrant 6" Size of Water main 8"
Static PSI 62 Residual PSI 52 Orifice size 4" Pitot 26
Fire Flow at 20 PSI 4749 Duration 2 Hours Flow Test Date / Time 11/28/2017 @ 4:43pm

Location _____

Distance from Nearest Property Line _____ Hydrant Number _____
Size of Hydrant _____ Size of Water main _____
Static PSI _____ Residual PSI _____ Orifice size _____ Pitot _____
Fire Flow at 20 PSI _____ Duration _____ Flow Test Date / Time _____

Location _____

Distance from Nearest Property Line _____ Hydrant Number _____
Size of Hydrant _____ Size of Water main _____
Static PSI _____ Residual PSI _____ Orifice size _____ Pitot _____
Fire Flow at 20 PSI _____ Duration _____ Flow Test Date / Time _____

PART II-B SPRINKLERED BUILDINGS/PRIVATE FIRE HYDRANTS ONLY

Detector Location (check one) Above Grade Below Grade Either
Backflow Protection Required (Fire Sprinklers/Private Hydrant) (check one) Yes No
Minimum Type of Protection Required (check one) Single Check Detector Assembly
 Double Check Detector Assembly Reduced Pressure Principle Detector Assembly

Golden State Water Company
Water Purveyor

[Signature]
Signature

11/28/2017
Date

Operations Engineer
Title

This information is Considered Valid for Twelve Months

Fire Department approval of building plans shall be required prior to the issuance of a Building Permit by the jurisdictional Building Department. Any deficiencies in water systems will need to be resolved by the Fire Prevention Division only prior to this department's approval of building plans.

PROJECT ADDRESS : 10223 Prairie Ave.